



January 11, 2023

(306) 741-7718

Via Email: [rm292.rm322@sasktel.net](mailto:rm292.rm322@sasktel.net)

RM of Milton  
Box 292  
Marengo, SK S0L 2K0

Attention Waterworks Owner/Operator:

**RE: Precautionary Drinking Water Advisory for *The Special Service Area of Alsask* - Rescinded**

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following the *power failure and* recent waterworks system depressurization. Therefore, effective immediately the WSA is rescinding the "**Precautionary Drinking Water Advisory**" for the residents and users of the *Special Service Area of Alsask's* water supply.

For further information, please do not hesitate to contact the undersigned at (306) 741-7718 or [Scott.Klippenstein@wsask.ca](mailto:Scott.Klippenstein@wsask.ca).

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Klippenstein", is written over a light blue horizontal line.

WATER SECURITY AGENCY  
Scott Klippenstein – A.Sc.T.  
Environment Officer

cc: Roger Miller, Manager, Compliance Promotion South, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Rosetown Office