



March 29, 2024

(306) 741-7718

Via Email: rm292.rm322@sasktel.net

RM of Milton
Box 292
Marengo, SK S0L 2K0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Special Service Area of Alsask* - Rescinded

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following the *system depressurization* recent waterworks system depressurization. Therefore, effective immediately the WSA is rescinding the “**Precautionary Drinking Water Advisory**” for the residents and users of the *Special Service area of Alsask’s* water supply.

For further information, please do not hesitate to contact the undersigned at (306) 741-7718 or Scott.Klippenstein@wsask.ca.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Klippenstein".

WATER SECURITY AGENCY
Scott Klippenstein – A.Sc.T.
Environment Officer

cc: Roger Miller, Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Rosetown Office