

April 24, 2026

306-741-7718

Via Email: rm292.rm322@sasktel.net; gcchiliak@live.ca; crittercory@gmail.com

Special Service Area of Alsask  
Box 70  
MARENGO SK S0L 2K0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Special Service Area of Alsask*: - Rescinded

The Water Security Agency, in consultation with Saskatchewan Health Authority is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Special Service Area of Alsask*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of three (6 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-741-7718 or Scott.Klippenstein@wsask.ca.

Sincerely,



Scott Klippenstein P.Tech.  
Environment Officer  
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Rosetown Office